

# Goble Water Association

## Drinking Water Report\*\*\*\*2024 Sampling Results

### We provide quality drinking water that meets all federal and state requirements.

During recent years we have sampled many different chemicals for contamination. Contamination is anything other than pure water. We sample total coliform bacteria as an indicator of microorganisms (bacteria, viruses and other small creatures) that should not be present. The table below lists all the drinking water contaminants that we detected during the past calendar year or in our most recent tests as noted. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate a health risk. More information about contaminants and potential health effects can be obtained by calling 503-732-0891 or U.S. Environmental Protection Agency's (EPA's) Safe Drinking Water Hotline (1-800-426-4791).

EPA's website is [www.epa.gov/safewater](http://www.epa.gov/safewater)

### Terms and Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. **IDEAL GOAL**

**Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. **HIGHEST LEVEL ALLOWED**

**Action Level (AL):** the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. **na:** not applicable **nd:** not detectable at testing limit **ppm:** parts per million or milligrams per liter (1 drop in 1 million gallons) **ppb:** parts per billion or micrograms per liter (1 drop in 1 billion gallons) **pCi/L:** picocuries per liter (a measure of radiation).

Regulated Contaminant	MCLG	MCL	Our Water	Sample Date	Exceedance / Violation	Typical Source of Contaminant
Nitrate (ppm)	10	10	1.81	7-15-24	No	Runoff from fertilizer
Lead (ppb)	0	15 AL	2.0	8-2-21	No	Corrosive water & home plumbing
Copper (ppm)	1.3	1.3 AL	0.066	8-5-24	No	Corrosive water & home plumbing
Total Haloacetic Acids (HAA5) (ppb)	n/a	60	1.6	8-8-22	No	Disinfection Byproduct
Total Trihalomethanes (TTHM) (ppb)	n/a	80	10.4	8-8-22	No	Disinfection Byproduct

### VIOLATIONS Below & Refer to Inside Page ##

State records indicate not being in compliance with state regulations to Issue a Public Notice and for Failure to Correct Source Contamination. We are working with the state and Oregon's Circuit Rider Program to make the necessary corrections.